

**Question:**

In light of the town pool being closed, we have had a few readers ask what water is supplied to Tindal pool and if tests are being done there?

**Response:**

The water from the Tindal pool is supplied from the Katherine Town Water.

The pool has been tested for PFAS and was found to be below the recreational guidelines at 0.45ug/L. Testing for PFAS levels in the pool will continue on a regular basis.

Tindal pool has been made available for school events and will become open to the Katherine Community from 11 October until the Katherine pool reopens.