

## RAAF Base Williamtown - Lake Cochran Water Treatment Plant

### Summary of Water sampling results for the period 10 March 2017 to 23 March 2017

Sampling of PFAS concentration levels in micrograms per litre ( $\mu\text{g/L}$ )

Date	PFOS + PFHxS Levels		PFOA Levels		6:2 FTS Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
10-03-17	5.01	<0.01	0.09	<0.01	<0.05	<0.05
13-03-17	6.36	<0.01	0.09	<0.01	<0.05	<0.05
14-03-17	5.79	<0.01	0.09	<0.01	<0.05	<0.05
15-03-17	6.79	0.01	0.08	<0.01	<0.05	<0.05
16-03-17	5.55	<0.01	0.07	<0.01	<0.05	<0.05
17-03-17	6.26	<0.01	0.16	<0.01	<0.05	<0.05
20-03-17	4.96	<0.01	0.07	<0.01	<0.05	<0.05
21-03-17	4.64	<0.01	0.06	<0.01	<0.05	<0.05
22-03-17	4.28	<0.01	0.08	<0.01	<0.05	<0.05
23-03-17	4.15	<0.01	0.06	<0.01	<0.05	<0.05

Results highlighted if Treated Water concentration is above the adopted drinking water screening criteria