

RAAF Base Williamtown - Lake Cochran Water Treatment Plant

Summary of Water sampling results for the period 16th June 2017 to 29th June 2017

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS + PFHxS Levels		PFOA Levels		6:2 FTS Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
16/06/2017	10.5	<0.01	0.12	<0.01	0.07	<0.05
19/06/2017	13.3	<0.01	0.18	<0.01	<0.05	<0.05
20/06/2017	16.9	<0.01	0.19	<0.01	<0.05	<0.05
21/06/2017	12.9	<0.01	0.14	<0.01	0.06	<0.05
22/06/2017	18	<0.01	0.21	<0.01	<0.05	<0.05
23/06/2017	7.69	<0.01	0.07	<0.01	<0.05	<0.05
26/06/2017	22.1	0.03	0.22	<0.01	0.12	<0.05
27/06/2017	14.7	0.03	0.18	<0.01	<0.05	<0.05
28/06/2017	14.2	<0.01	0.18	<0.01	<0.05	<0.05
29/06/2017	13.4	<0.01	0.15	<0.01	<0.05	<0.05

Results highlighted if Treated Water concentration above adopted drinking water screening criteria