

RAAF Base Williamtown - Lake Cochran Water Treatment Plant

Summary of Water sampling results for the period 11 August 2017 to 24 August 2017

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS + PFHxS Levels		PFOA Levels		6:2 FTS Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
11-08-17	3.78	<0.01	0.06	<0.01	<0.05	<0.05
14-08-17	2.85	<0.01	0.04	<0.01	<0.05	<0.05
15-08-17	3.84	<0.01	0.06	<0.01	<0.05	<0.05
16-08-17	2.84	<0.01	0.05	<0.01	<0.05	<0.05
17-08-17	3.69	<0.01	0.06	<0.01	0.05	<0.05
18-08-17	2.23	<0.01	0.03	<0.01	<0.05	<0.05
21-08-17	2.62	<0.01	0.03	<0.01	<0.05	<0.05
22-08-17	3.12	<0.01	0.06	<0.01	0.07	<0.05
23-08-17	2.62	<0.01	0.05	<0.01	<0.05	<0.05
24-08-17	2.51	<0.01	0.06	<0.01	0.08	<0.05

Results highlighted if Treated Water concentration above adopted drinking water screening criteria