

RAAF Base Williamstown - Lake Cochran Water Treatment Plant

Summary of Water sampling results for the period 15th December 2017 to 28th December 2017

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS + PFHxS Levels		PFOA Levels		6:2 FTS Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
15-12-17	1.86	<0.01	0.04	<0.01	<0.05	<0.05
18-12-17	1.79	<0.01	0.04	<0.01	<0.05	<0.05
19-12-17	2.60	<0.01	0.05	<0.01	0.05	<0.05
20-12-17	1.79	<0.01	0.05	<0.01	<0.05	<0.05
21-12-17	1.93	<0.01	0.05	<0.01	<0.05	<0.05
22-12-17	2.26	<0.01	0.05	<0.01	0.05	<0.05
27-12-17	2.61	<0.01	0.05	<0.01	0.06	<0.05
28-12-17	3.55	<0.01	0.06	<0.01	0.10	<0.05

Results highlighted if Treated Water concentration above adopted drinking water screening criteria