

RAAF Base Williamstown - Lake Cochran Water Treatment Plant

Summary of Water sampling results for the period 19th May 2017 to 1st June 2017

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS + PFHxS Levels		PFOA Levels		6:2 FTS Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
19-05-17	4.13	<0.01	0.06	<0.01	<0.05	<0.05
22-05-17	4.17	<0.01	0.06	<0.01	<0.05	<0.05
23-05-17	3.74	<0.01	0.06	<0.01	0.06	<0.05
24-05-17	3.15	<0.01	0.04	<0.01	<0.05	<0.05
25-05-17	5.30	<0.01	0.09	<0.01	0.08	<0.05
26-05-17	4.6	<0.01	0.06	<0.01	<0.05	<0.05
29-05-17	3.42	<0.01	0.05	<0.01	0.09	<0.05
30-05-17	4.31	<0.01	0.07	<0.01	0.06	<0.05
31-05-17	4.28	<0.01	0.06	<0.01	0.06	<0.05
01-06-17	4.37	<0.01	0.07	<0.01	0.08	<0.05

Results highlighted if Treated Water concentration above adopted drinking water screening criteria