

## RAAF Base Williamtown - Lake Cochran Water Treatment Plant

### Summary of Water sampling results for the period 24 March 2017 to 6 April 2017

Sampling of PFAS concentration levels in micrograms per litre ( $\mu\text{g/L}$ )

Date	PFOS + PFHxS Levels		PFOA Levels		6:2 FTS Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
24-03-17	3.66	<0.01	0.06	<0.01	<0.05	<0.05
27-03-17	4.05	<0.01	0.06	<0.01	<0.05	<0.05
28-03-17	3.75	<0.01	0.07	<0.01	<0.05	<0.05
29-03-17	3.81	<0.01	0.06	<0.01	<0.05	<0.05
30-03-17	3.67	<0.01	0.06	<0.01	<0.05	<0.05
31-03-17	4.65	<0.01	0.06	<0.01	<0.05	<0.05
03-04-17	4.08	<0.01	0.06	<0.01	<0.05	<0.05
04-04-17	4.12	<0.01	0.07	<0.01	0.06	<0.05
05-04-17	5.27	<0.01	0.08	<0.01	0.06	<0.05
06-04-17	4.83	<0.01	0.06	<0.01	<0.05	<0.05

Results highlighted if Treated Water concentration is above the adopted drinking water screening criteria