

JBS&G (43153-58005)

19 June 2014

Doug Wu
Project Manager
Boulderstone Pty Ltd
Via email: Doug.Wu@lendlease.com

**AMR 117 - Daily Airborne Asbestos Fibre Monitoring
Randwick Barracks, 373a Avoca Street, Randwick NSW**

Dear Doug,

Please find as **Attachment 1** the daily airborne asbestos fibre monitoring report for works completed at the Randwick Barracks Project site on **18 June 2014**.

All air monitoring was completed in strict accordance with the *Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres* [NOHSC: 3003(2005)], with NATA certification applying to all sample collection, handling and analytical procedures.

All reported results were satisfactory and below the minimum action levels for control monitoring as outlined in:

- Work, Health and Safety (2011) Regulation; and
- WorkCover Authority of NSW (2011) Code of Practice – *How to Safely Remove Asbestos*.

If you have any questions regarding these results, please feel free to contact the undersigned on 02 8245 0300 or by email msamuel@jbsg.com.au.

Yours sincerely:



Michael Samuel
Licensed Asbestos Assessor (LAA 000157)
JBS&G

Attachments: 1) Daily Airborne Asbestos Fibre Monitoring Report

Attachment 1 – Daily Airborne Asbestos Fibre Monitoring Report

Certificate of Analysis



NATA Accredited
Accreditation Number 1261
Site Number 1254

Accredited for compliance with ISO/IEC 17025.
The results of the tests, calibrations and/or
measurements included in this document are
traceable to Australian/national standards.

JBS & G (NSW & WA) Pty Ltd
Level 1, 50 Margaret St
Sydney
NSW 2000

Attention: Michael Samuel
Report: 422241-A
Client Reference: **43153 RANDWICK**
Received Date: 18 June 2014
Date Reported: 18 June 2014

METHODOLOGY:

Asbestos Sampling	Sampling as per the National Occupational Health & Safety Commission - Guidance Note on The Membrane Filter Method For Estimating Airborne Asbestos Fibres 2 nd Edition [NOHSC:3003(2005)]
Pump Calibration	Mini Buck Model M-5 S/N A54456 : Calibrated against National Bureau of Standards Test No. IR74-461 utilising a 1000 ml burette with an electric stop watch (SW1).
Asbestos Counting	Conducted by ASET in accordance with the National Occupational Health & Safety Commission - Guidance Note on The Membrane Filter Method For Estimating Airborne Asbestos Fibres 2 nd Edition [NOHSC:3003(2005)] and (ASET Method 2).

Site Reference: 43153 RANDWICK
Date Sampled: 18 June 2014
Report: 422241-A

Eurofins mgt Sample No.	Client Sample ID	Pump ID	Location	Start (time)	End (time)	Start Flow Rate (L/min)	End Flow Rate (L/min)	Average Flow Rate (L/min)	Fibres / 100 fields	Result (Fibres/mL)
14-Jn14898	A382	SKC 003	NORTH PORTION OF SITE SOUTH BOUNDARY - PATHWAY	7:45	13:42	1.5	1.5	1.5	0.0	< 0.01
14-Jn14899	A380	SKC 011	NORTH PORTION WEST BOUNDARY - ACCESS ROAD	7:47	13:45	1.5	1.5	1.5	2.0	< 0.01
14-Jn14900	A383	SKC 130	NORTH PORTION EAST BOUNDARY - SITE SHEDS	7:49	13:47	1.5	1.5	1.5	2.5	< 0.01
14-Jn14901	A357	SKC 136	NORTH PORTION EAST BOUNDARY - FIELD	7:52	13:49	1.5	1.5	1.5	0.5	< 0.01
14-Jn14902	A355	SKC 138	SOUTH PORTION SOUTH BOUNDARY - HOUSES	7:55	13:52	1.5	1.5	1.5	0.0	< 0.01
14-Jn14903	A371	SKC 143	SOUTH PORTION WEST BOUNDARY - AVOCA STREET SOUTH	7:58	13:54	1.5	1.5	1.5	1.0	< 0.01
14-Jn14904	A381	SKC 144	SOUTH PORTION NORTH BOUNDARY - SITE ENTRY	8:01	13:56	1.5	1.5	1.5	1.0	< 0.01
14-Jn14905	A354	SKC 149	SOUTH PORTION WEST BOUNDARY - AVOCA STREET NORTH	8:03	13:58	1.5	1.5	1.5	1.5	< 0.01
14-Jn14906	A362	SKC 008	NORTH PORTION INSIDE LUNCH ROOM	8:10	14:00	1.5	1.5	1.5	1.0	< 0.01
14-Jn14907	A385	BLANK	BLANK						0.0	

Comments

Asbestos analysed by: ASET, NATA accreditation no. 14484, report reference: ASET39832/43012/1-10

Sample Integrity

Custody Seals Intact (if used)	N/A
Attempt to Chill was evident	No
Sample correctly preserved	Yes
Organic samples had Teflon liners	N/A
Sample containers for volatile analysis received with minimal headspace	N/A
Samples received within Holding Time	Yes
Some samples have been subcontracted	Yes

Qualifier Codes/Comments

Code	Description
N/A	Not applicable

Authorised by

Jean Heng Client Services



Peter Richardson
Field Services Manager

Final Report – this report replaces any previously issued Report.

- Indicates Not Requested

* Indicates NATA accreditation does not cover the performance of this service

Uncertainty data is available on request

Eurofins | mgt shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Eurofins | mgt be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report. This document shall not be reproduced except in full and relates only to the items tested. Unless indicated otherwise, the tests were performed on the samples as received.